FIRE SAFETY CERTIFICATE

No: 70/2024

Dated: 04.06.2024

Nos:196/1, Emerald Valley, Yercaud Foot hills Kondappanaikenpatty Village, Salem Taluk, Salem District, Tamilnadu State, Pin: 636008 comprised of four blocks owned by SETHU MEENAKSHI CHARITIES (by way of Sale Deed dated 06/03/1995) and further certified that the owner of the land has leased the said land to M/s. EMERALD VALLEY PUBLIC SCHOOL (run by SETHU MEENAKSHI CHARITIES) for a period of 30 years from 26.06.2009 to 25.06.2039 have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 04.06.2024 in the presence of Mrs. S, Meenakshi, Correspondent, EMERALD VALLEY PUBLIC SCHOOL, SALEM – 8 at Survey Nos: 196 / 1, Emerald Valley, Yercaud Foot hills, Kondappanaikenpatty Village, Salem Taluk, Salem District, Tamilnadu State, Pin: 636008 and that the premises is fit for occupancy upto classes XII with effect from 04.06.2024 for a period of One Year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1. This certificate is valid for One Year from the date of issue.
- Fire protection devices shall be placed in (Generator room, Class room, Laboratory and Computer room) the wall or easy to handle as per provisions of National Building Code 2015 and Indian Standards.
- 3. Water Tanks should always be kept in full.
- Mock drill should be conducted periodically.
- 5. Emergency exit signs should be kept in red colour that even glows in the dark.
- 6. First Aid Kit should be kept and used properly.
- 7. Do not accumulate waste materials in the School premises.
- 8. Cooking room should be separate from the School building and LPG gas cylinders should be used safely without leakage.

Issued on 03.06.2024 at SALEM by

Date Albizon

LEM-636 001

The Correspondent,

EMERALD VALLEY PUBLIC SCHOOL,

Survey Nos: 196/1

To:-

Yercaud Foot hills, Kondappanaikenpatty Village,

Salem Taluk, Salem District, Tamil Nadu State, Pin: 636008 Assistant District Officer Fire and Rescue Services Salem-636 001 Salem District